

**List of 2019 Non-Detected Contaminants
Monitored December 2019**

INORGANIC METALS	Concentration detected µg/L	MCL	SYNTHETIC ORGANIC COMPOUNDS	Concentration detected µg/L	MCL
Antimony	<0.40	6.00			
Arsenic	<0.50	10.00	Methyl Carbamate Pesticides		
Beryllium	<0.30	4.00	Aldicarb	<0.50	3.00
Cadmium	<1.00	5.00	Aldicarb Sulfone	<0.80	2.00
Chromium	<1.00	100.00	Aldicarb Sulfoxide	<0.50	4.00
Cyanide	<5.00	200.00	Carbaryl	<0.50	50.00
Fluoride	<100.0	4000.00	Carbofuran	<0.90	40.00
Iron	<10.0	300.00	3-Hydroxy Carbofuran	<0.50	50.00
Mercury	<0.20	2.00	Methomyl	<0.50	50.00
Nickel	<1.00	100.00	Oxamyl	<2.0	200.00
Selenium	<1.0	50.00			
Thallium	<0.3	2.00			
Silver	<1.00	100.00			
Nitrite	<4.0	1000.00			
			Micro Extractables		
SYNTHETIC ORGANIC CHEMICALS			1,2-Dibromoethane (EDB)	<0.010	0.05
Alachlor	<0.05	2.00	1,2-Dibromo-3-chloropropane	<0.020	0.20
Aldrin	<0.10				
Atrazine	<0.05	3.00			
Benzo(a)pyrene	<0.020	0.20	Chlorinated Herbicides		
Butachlor	<0.05	50.00	2,4-D	<0.10	50.00
Bis(2-ethylhexyl) phthalate	<0.57	6.00	Dalapon	<1.00	200.00
Bis(2-ethylhexyl) adipate	<0.57	50.00	Dicamba	<0.50	50.00
Dieldrin	<0.030	5.00	Dichloroprop	<0.50	
Endrin	<0.010	2.00	Dinoseb	<0.20	7.00
Heptachlor	<0.04	0.40	Pentachlorophenol	<0.040	1.00
Heptachlor epoxide	<0.020	0.20	Pichloram	<0.10	500.00
Hexachlorobenzene	<0.05	1.00	2,4,5-T	<0.50	
Hexachlorocyclopentadiene	<0.05	50.00	2,4,5-TP	<0.20	50.00
Lindane	<0.02	0.20			
Methoxychlor	<0.05	40.00			
Metolachlor	<0.10	50.00	Organohalide Pesticides & PCB's		
Metribuzin	<0.05	50.00	PCB, Total	<0.10	0.50
Simazine	<0.050	4.00	Chlordane Total	<0.19	2.00
			Propachlor	<0.05	
			Toxaphene	<0.95	3.00
			Various PCBs Screend	ND	0.50

**List of 2019 Non-Detected Contaminants
Monitored December 2019**

VOLATILE ORGANICS	Concentration detected µg/L	MCL	VOLATILE ORGANICS	Concentration detected µg/L	MCL
Benzene	<0.50	5.00	1,1-Dichloropropene	<0.50	5.00
Bromobenzene	<0.50	5.00	Cis-1,3-dichloropropene	<0.40	5.00
Bromochloromethane	<0.50	5.00	Trans 1,3-dichloropropene	<0.40	5.00
Bromoform	<0.50	5.00	Ethylbenzene	<0.50	5.00
Bromomethane	<0.50	5.00	Hexachlorobutadiene	<0.50	5.00
N-Butylbenzene	<0.50	5.00	Isopropylbenzene	<0.50	5.00
Sec-Butylbenzene	<0.50	5.00	p-Isopropyltoluene	<0.50	5.00
Tert-butylbenzene	<0.50	5.00	Methylene chloride	<0.50	5.00
Carbon tetrochloride	<0.50	5.00	Methyl-t-butyl Ether (MTBE)	<0.50	10.00
Chlorobenzene	<0.50	5.00	n-Propylbenzene	<0.50	5.00
Chloroethane	<0.50	5.00	Styrene	<0.50	5.00
Chloromethane	<0.50	5.00	1,1,2,2-Tetrachloroethane	<0.50	5.00
2-Chlorotoluene	<0.50	5.00	1,1,1,2-Tetrachloroethane	<0.50	5.00
4-Chlorotoluene	<0.50	5.00	Tetrachloroethene	<0.50	5.00
Dibromomethane	<0.50	5.00	Toluene	<0.50	5.00
1,2-Dibromomethane	<0.01	5.00	1,2,3-Trichlorobenzene	<0.50	5.00
1,2-Dichlorobenzene	<0.50	5.00	1,2,4-Trichlorobenzene	<0.50	5.00
1,3-Dichlorobenzene	<0.50	5.00	1,1,1-Trichloroethane	<0.50	5.00
1,4-Dichlorobenzene	<0.50	5.00	1,1,2-Trichloroethane	<0.50	5.00
Dichlorodifluoromethane	<0.50	5.00	Trichloroethene	<0.50	5.00
1,1-Dichloroethane	<0.50	5.00	Trichlorofluoromethane	<0.50	5.00
1,2-Dichloroethane	<0.50	5.00	1,2,3-Trichloropropane	<0.50	5.00
1,1-Dichloroethene	<0.50	5.00	1,2,4-Trimethylbenzene	<0.50	5.00
Cis-1,2-dichloroethene	<0.50	5.00	1,3,5-Trimethylbenzene	<0.50	5.00
Trans-1,2-dichloroethene	<0.50	5.00	Vinyl-Chloride	<0.50	2.00
1,2-Dichloropropane	<0.50	5.00	m-Xylene	<0.50	5.00
1,3-Dichloropropane	<0.50	5.00	o-Xylene	<0.50	5.00
2,2-Dichloropropane	<0.50	5.00	p-Xylene	<0.50	5.00