

List of 2024 Non-Detected Contaminants

INORGANIC METALS	Concentration detected µg/L	MCL	SYNTHETIC ORGANIC COMPOUNDS	Concentration detected µg/L	MCL
Antimony	<0.4	6.00	Methyl Carbamate Pesticides		
Arsenic	<1.0	10.00	1-Naphthol	<1.0	
Beryllium	<0.3	4.00	Aldicarb	<0.5	3.00
Cadmium	<1.0	5.00	Aldicarb Sulfone	<0.7	2.00
Chromium	<5.0	100.00	Aldicarb Sulfoxide	<0.5	4.00
Cyanide	<10.0	200.00	Carbaryl	<0.5	50.00
Fluoride	<100.0	2200.00	Carbofuran	<0.90	40.00
Iron	<50.0	300.00	3-Hydroxy Carbofuran	<0.50	50.00
Manganese	<5.0	300.00	Methomyl	<0.5	50.00
Mercury	<0.2	2.00	Oxamyl	<1.0	50.00
Nickle	<0.5	100.00	Organohalide Pesticides & PCB's		
Selenium	<1.0	50.00	Chlordane	<0.2	2.00
Silver	<5.0	100.00	Propachlor	<0.10	50.00
Thallium	<0.3	2.00	Toxaphene	<1.0	3.00
Zinc	<10.0	5000.00			
Nitrite as N	<10.0	1000.00	1,4 Dioxane	< 0.070	1.00
Nitrate as N	<10.0	10000.00			

*SYNTHETIC ORGANIC CHEMICALS			Per & Polyfluoroalkyl Substance	ng/L	Not Regulated
Alachlor 1016,1221,1232,1242,1248,1254,1260	<0.065	2.00	Perfluorobutanoic acid (PFBA)	<1.9	
Aldrin	<0.05	5.00	Perfluoropentanoic acid (PFPeA)	<1.9	
Atrazine	<0.10	3.00	Perfluorohexanoic acid (PFHxA)	<1.9	
Benzo(a)pyrene	<0.02	0.20	Perfluoroheptanoic acid (PFHpA)	<1.9	
Butachlor	<0.10	50.00	Perfluorooctanoic acid (PFOA)	<1.9	4.0 ng/L
Di(2-ethylhexyl) adipate	<0.60	50.00	Perfluorononanoic acid (PFNA)	<1.9	10.0 ng/L
Di(2-ethylhexyl) phthalate	<0.60	6.00	Perfluorodecanoic acid (PFDA)	<1.9	
Dieldrin	<0.1	5.00	Perfluoroundecanoic acid (PFUnA)	<1.9	
Endrin	<0.01	2.00	Perfluorododecanoic acid (PFDoA)	<1.9	
Heptachlor	<0.01	0.40	Perfluorobutanesulfonic acid (PFBS)	<1.9	
Heptachlor epoxide	<0.01	0.20	Perfluoropentanesulfonic acid	<1.9	
Hexachlorobenzene	<0.10	1.00	Perfluorohexanesulfonic acid	<1.9	10.0 ng/L
Hexachlorocyclopentadiene	<0.1	5.00	Perfluoroheptanesulfonic acid	<1.9	
Lindane	<0.02	0.20	Perfluoro (2-ethoxyethane) sulfonic acid	<1.9	
Methoxychlor	<0.10	40.00	1H,1H,2H,2H-Perfluorohexane SA	<1.9	
Metolachlor	<0.10	50.00	1H,1H,2H,2H-Perfluorooctane SA	<1.9	
Metribuzin	<0.10	50.00	1H,1H,2H,2H-Perfluorodecane SA	<1.9	
Simazine	<0.07	4.00	HFPO-DA	<1.9	10.0 ng/L
Chlorinated Herbicides			4,8-Dioxa-3H-perfluorononanoic acid	<1.9	
2,4-D	<0.10	50.00	9-Chlorohexadecafluoro-3-oxanonane SA	<1.9	
Dalapon	<1.0	50.00	PFMBA	<1.9	
Dicamba	<0.10	50.00	PFMPA	<1.9	
Dinoseb	<0.10	7.00	NFDHA	<1.9	
Picloram	<0.10	50.00			
2,4,5-TP (Silvex)	<0.1	10.00			
Pentachlorophenol	<0.040	1.00			

List of 2024 Non-Detected Contaminants

VOLATILE ORGANICS	Concentration detected µg/L	MCL	VOLATILE ORGANICS	Concentration detected µg/L	MCL
Benzene	<0.5	5.00	1,1-Dichloropropene	<0.5	5.00
Bromobenzene	<0.5	5.00	cis 1,3-dichloropropene	<0.5	5.00
Bromochloromethane	<0.5	5.00	trans1,3-dichloropropene	<0.5	5.00
Bromform	<0.5	5.00	Ethylbenzene	<0.5	5.00
Bromomethane	<0.5	5.00	Hexachloro-1,3-butadiene	<0.5	5.00
N-Butylbenzene	<0.5	5.00	Isopropylbenzene	<0.5	5.00
Sec-Butylbenzene	<0.5	5.00	4-Isopropyltoluene	<0.5	5.00
Tert-butylbenzene	<0.5	5.00	Methylene chloride	<0.5	5.00
Carbon tetrochloride	<0.5	5.00	Methyl-t-butyl Ether (MTBE)	<0.5	10.00
Chlorobenzene	<0.5	5.00	n-Propylbenzene	<0.5	5.00
Chloroethane	<0.5	5.00	Styrene	<0.5	5.00
Chloromethane	<0.5	5.00	1,1,2,2,-Tetrachloroethane	<0.5	5.00
2-Chlorotoluene	<0.5	5.00	1,1,1,2-Tetrachloroethane	<0.5	5.00
4-Chlorotoluene	<0.5	5.00	Tetrachloroethene	<0.5	5.00
Dibromomethane	<0.5	5.00	Toluene	<0.5	5.00
Dibromochloromethane	<0.5	5.00	1,2,3-Trichlorobenzene	<0.5	5.00
1,2-Dichlorobenzene	<0.5	5.00	1,2,4-Trichlorobenzene	<0.5	5.00
1,3-Dichlorobenzene	<0.5	5.00	1,1,1-Trichloroethane	<0.5	5.00
1,4-Dichlorobenzene	<0.5	5.00	1,1,2-Trichloroethane	<0.5	5.00
Dichlorodifluoromethane	<0.5	5.00	Trichloroethene	<0.5	5.00
1,1-Dichloroethane	<0.5	5.00	Trichlorofluoromethane	<0.5	5.00
1,2-Dichloroethane	<0.5	5.00	1,2,3-Trichloropropane	<0.5	5.00
1,1-Dichloroethene	<0.5	5.00	1,2,4-Trimethylbenzene	<0.5	5.00
Cis-1,2-dichloroethene	<0.5	5.00	1,3,5-Trimethylbenzene	<0.5	5.00
Trans-1,2-dichloroethene	<0.5	5.00	Vinyl-Chloride	<0.5	2.00
1,2-Dichloropropane	<0.5	5.00	m&p-Xylene	<0.5	5.00
1,3-Dichloropropane	<0.5	5.00	o-Xylene	<0.5	5.00
2,2-Dichloropropane	<0.5	5.00		<0.5	5.00
*All Contaminants were analyzed in June.2024					