City of Albany Water Quality Laboratory 501 Old Quarry Road Selkirk, New York 12158

Sampling location: Entry Point to Distribution System at Feura Bush treatment Plant

PFOA - NYS MCLs: 10ng/L or 10ppt)

PFOS - NYS MCLs: 10ng/L or 10ppt)

1,4-Dioxane - NYS MCLs: $1\mu g/L$ or 1ppb)

Quarter	1st Q 2020	2nd Q	3rd Q 2021	4th Q 2021
Date Sampled	9/16/2020	12/16/2020	3/17/2021	6/16/2021
Perfluorooctanic Acid	< 0.8* ng/L	< 0.82* ng/L	< 0.81* ng/L	
Perfluorooctane Sulfonate	< 0.74* ng/L	< 1.1* ng/L	< 1.1* ng/L	
1,4 Dioxane	< 0.0081* ug/l	<0.018* ug/L	< 0.0081* ug/l	

^{*} Below Detection limits