

List of 2022 Non-Detected Contaminants

INORGANIC METALS	Concentration detected µg/L	MCL	SYNTHETIC ORGANIC COMPOUNDS	Concentration detected µg/L	MCL
Antimony	<0.060	6.00	<b>Methyl Carbamate Pesticides</b>		
Beryllium	<0.028	4.00	Aldicarb	<0.33	3.00
Cadmium	<0.10	5.00	Aldicarb Sulfone	<0.58	2.00
Cyanide	<7.2	200.00	Aldicarb Sulfoxide	<0.47	4.00
Bromide	<0.020	10.00	Carbaryl	<0.33	50.00
Fluoride	<0.040	4000.00	Carbofuran	<0.59	40.00
Iron	<8.9	300.00	3-Hydroxy Carbofuran	<0.33	50.00
Mercury	<0.025	2.00	Methomyl	<0.31	50.00
Selenium	<0.31	50.00	Oxamyl	<0.46	200.00
Silver	<0.11	100.00	<b>Organohalide Pesticides &amp; PCB's</b>		
Zinc	<0.98	5000.00	Chlordane	<0.060	2.00
Nitrite as N	<0.027	1000.00	Propachlor	<0.010	
Nitrate as N	<0.037	10000.00	Toxaphene	<0.62	3.00
Nitrate-Nitrite (as N)	<0.037	10000.00	PCB Screen	<0.20	0.50
<b>SYNTHETIC ORGANIC CHEMICALS</b>			<b>Micro Extractables</b>		
Alachlor	<0.025	2.00	1,2-Dibromoethane (EDB)	<0.0055	0.05
Aldrin	<0.0055		1,2-Dibromo-3-chloropropane	<0.0082	0.20
Atrazine	<0.016	3.00	1,2,3-Trichloropropane	<0.0028	0.20
Benzo(a)pyrene	<0.0074	0.20			
Butachlor	<0.026	50.00	<b>1,4 Dioxane</b>	< 0.018	1.00
Bis(2-ethylhexyl) phthalate	<0.11	6.00	<b>Per &amp; Polyfluoroalkyl Substances</b>	<b>ng/L</b>	<b>Not Regulated</b>
Bis(2-ethylhexyl) adipate	<0.025	50.00	11Cl-PF3OUdS	<0.40	
Dieldrin	<0.0025	5.00	4:2 FTS	<0.51	
Endrin	<0.0046	2.00	6:2 FTS	<3.2	
Heptachlor	<0.029	0.40	8:2 FTS	<0.43	
Heptachlor epoxide	<0.0084	0.20	9Cl-PF3ONS	<0.45	
Hexachlorobenzene	<0.0049	1.00	ADONA	<0.39	
Hexachlorocyclopentadiene	<0.044	50.00	HFPO-DA	<0.66	
Lindane	<0.018	0.20	NFDHA	<0.26	
Methoxychlor	<0.029	40.00	Perfluorobutanesulfonic acid	<0.39	
Metolachlor	<0.012	50.00	Perfluorodecanoic acid	<0.28	
Metribuzin	<0.025	50.00	PFEESA	<0.32	
Simazine	<0.013	4.00	PFHpS	<0.36	
<b>Chlorinated Herbicides</b>			PFMBA	<0.24	
2,4-D	<0.034	50.00	PFMPA	<0.30	
Dicamba	<0.85	50.00	PFPeS	<0.32	
Dinoseb	<0.20	7.00	Perfluorododecanoic acid	<0.48	
Picloram	<0.094	500.00	Perfluoroheptanoic acid	<0.40	
2,4,5-TP (Silvex)	<0.070	50.00	Perfluorohexanesulfonic acid	<0.33	
			Perfluorononanoic acid	<0.30	
			Perfluorooctanesulfonic acid	<0.32	
			Perfluoroundecanoic acid	<0.38	

List of 2022 Non-Detected Contaminants

VOLATILE ORGANICS	Concentration detected µg/L	MCL	VOLATILE ORGANICS	Concentration detected µg/L	MCL
Benzene	<0.22	5.00	1,1-Dichloropropene	<0.21	5.00
Bromobenzene	<0.18	5.00	cis 1,3-dichloropropene	<0.17	5.00
Bromochloromethane	<0.21	5.00	trans1,3-dichloropropene	<0.21	5.00
Bromform	<0.35	5.00	Ethylbenzene	<0.22	5.00
Bromomethane	<0.48	5.00	Hexachloro-1,3-butadiene	<0.16	5.00
N-Butylbenzene	<0.17	5.00	Isopropylbenzene	<0.19	5.00
Sec-Butylbenzene	<0.18	5.00	p-Isopropyltoluene	<0.20	5.00
Tert-butylbenzene	<0.19	5.00	Methylene chloride	<0.21	5.00
Carbon tetrochloride	<0.17	5.00	Methyl-t-butyl Ether (MTBE)	<0.38	10.00
Chlorobenzene	<0.19	5.00	n-Propylbenzene	<0.18	5.00
Chloroethane	<0.25	5.00	Styrene	<0.19	5.00
Chloromethane	<0.49	5.00	1,1,2,2,-Tetrachloroethane	<0.18	5.00
2-Chlorotoluene	<0.21	5.00	1,1,1,2-Tetrachloroethane	<0.35	5.00
4-Chlorotoluene	<0.25	5.00	Tetrachloroethene	<0.19	5.00
Dibromomethane	<0.42	5.00	Toluene	<0.22	5.00
Dibromochloromethane	<0.15	5.00	1,2,3-Trichlorobenzene	<0.41	5.00
1,2-Dichlorobenzene	<0.20	5.00	1,2,4-Trichlorobenzene	<0.47	5.00
1,3-Dichlorobenzene	<0.20	5.00	1,1,1-Trichloroethane	<0.19	5.00
1,4-Dichlorobenzene	<0.22	5.00	1,1,2-Trichloroethane	<0.17	5.00
Dichlorodifluoromethane	<0.22	5.00	Trichloroethene	<0.21	5.00
1,1-Dichloroethane	<0.23	5.00	Trichlorofluoromethane	<0.15	5.00
1,2-Dichloroethane	<0.22	5.00	1,2,3-Trichloropropane	<0.40	5.00
1,1-Dichloroethene	<0.20	5.00	1,2,4-Trimethylbenzene	<0.18	5.00
Cis-1,2-dichloroethene	<0.18	5.00	1,3,5-Trimethylbenzene	<0.19	5.00
Trans-1,2-dichloroethene	<0.24	5.00	Vinyl-Chloride	<0.23	2.00
1,2-Dichloropropane	<0.20	5.00	Xylene (total)	<0.14	5.00
1,3-Dichloropropane	<0.18	5.00	m&p-Xylene	<0.24	5.00
2,2-Dichloropropane	<0.23	5.00	o-Xylene	<0.20	5.00